

PROJECT: PADUCAH SPORTS PARK – MCCracken COUNTY

DATE OF ISSUE: OCTOBER 8th, 2025

Re: REQUEST FOR PRICING - SIGNAGE

ADDENDUM NO. 2

This Document is an amendment of the original Request For Proposal as issued. Wherein this Addendum conflicts with the original RFP, Specifications and/or Drawings, this Addendum shall govern.

BIDDER'S QUESTIONS

The following questions were received from interested parties regarding this RFP.

QUESTION #1 **Specifications and visual representation are missing for the following Signs:**

- **Sign Type F1 (Distance Signs), F31–F35 (Qty: 5)**
- **Sign Type F2 (Dugout Signs): F36–F55 (Qty: 20)**
- **Sign Type F3 (Field Netting Signs): F56–F74 (Qty: 19)**

ANSWER #1 All Field Sign Types F1, F2, F3 are now Type 7 Signs as shown on the bid form and message schedule. Type 7 specifications are shown on the attached drawings: [20250731 Signage_BidPackage.pdf](#) and in the RFP.

QUESTION #2 **Unable to find sign type W13 – Monument – Custom in the drawings.**

ANSWER #2 Sign type W13 is shown on the message schedule and should read "Paducah Sports Park". Shall be aluminum letters and constructed similar to W21 shown on the drawings.

QUESTION #3 **Unable to find sign type W35 - Dedication Plaque in the drawings.**

ANSWER #3 The dedication plaque is shown on the drawings and shall be 30" X 20". The attached link shows visual representation of the plaque: [DEDICATION SIGN VISUAL REPRESENTATION.pdf](#). **Draft language on the visual representation is only for bidding purposes. Actual Language to be approved by owner.**

QUESTION #4

Will the bid date change?

ANSWER #4

No, the bid date will not change and is still due Oct 15th per addendum #1.

QUESTION #5

Will there be an additional addendum?

ANSWER #5

No, there is not enough time to have an additional addendum per bid due date. Please send bid per addendum and revised RFP.

ATTACHMENTS

1. Signage Bid Package Drawings, Dedication plaque Visual.

END OF ADDENDUM NO. 2